

JSC Safety and Health Requirements	JPR No.	1700.1
	Effective Date:	10/02/2024
	Expiration Date:	10/02/2029
	Page Number	Page 6.11-1 of 4

CHAPTER 6.11 LOCAL CHEMICAL HAZARD ALARMS

6.11.1. Applicability of this chapter

6.11.1.1 You are required to follow this chapter if you:

- a. Have a hazardous operation in your work area that uses an alarm system to warn of an air quality problem due to airborne contaminants.
- b. Manage or supervise a work area or facility containing an alarm system that warns of a hazardous airborne chemical.
- c. Enter a facility with an alarm system to warn of a hazardous airborne chemical.

6.11.2. What this chapter covers

This chapter covers the requirements for using local hazard alarms to control exposures to hazardous materials. It includes information for assessing the need for an alarm, registration of the alarm, alarm care and recordkeeping, and response requirements for facility occupants.

6.11.3. Examples of hazard alarm systems found at JSC, Sonny Carter Training Facility, and Ellington Field

- a. Carbon monoxide alarms in the high bay of Building 31.
- b. Oxygen deficiency alarms found in various rooms in Buildings 7, 15, 17, 21, 31, and 31N.
- c. Ammonia alarm found in Building 24.

NOTE: You can find a [list of alarms](#) at URL:

<https://nasa.sharepoint.com/sites/jsc-oh/SitePages/ChemicalAlarms.aspx>.

6.11.4. Alarms not covered by this chapter

Examples of alarms not covered by this chapter are those that do not alert people to a chemical hazard, such as fire alarms, freezer alarms, security alarms, equipment overheat, water leakage, etc.

JSC Safety and Health Requirements	JPR No.	1700.1
	Effective Date:	10/02/2024
	Expiration Date:	10/02/2029
	Page Number	Page 6.11-2 of 4

6.11.5. How to decide if you need an alarm in your work area

Supervisors are responsible for doing a hazard analysis for all hazardous chemical use areas. Refer to the work area’s hazard analysis or job hazard analysis to determine whether an alarm is required. Also review Chapter 6.9, “Confined Spaces and Controlled Areas,” and Chapter 9.1, “Hazardous Materials Safety and Health.” Whether or not an alarm is needed is based on many factors, including chemical quantities, chemical physical properties, toxicity, facility layout, ventilation, and others. If you have or believe you need a chemical alarm, consult Occupational Health at x36726 or jsc-dl-occ-health@mail.nasa.gov for advice on whether the alarm should be registered with or connected to the Emergency Operations Center. The decision is usually based on the results of a hazard analysis.

6.11.6. If you need an alarm in a work area

6.11.6.1 When an alarm is needed for chemical exposure detection, management shall:

- a. Register the alarm with Occupational Health for inclusion in the JSC inventory. Submit JSC form 1879, “JSC Chemical Hazard Alarm Registration,” along with a copy of the hazard analyses to Occupational Health, (x36726) or jsc-dl-occ-health@mail.nasa.gov. The form requires specific information, including alarm owner, alarm type, chemicals of interest, location, calibration, maintenance, and recordkeeping. Occupational Health will assign an individualized registration number to the alarm and place it into the alarm-monitoring program. All fixed in place chemical alarms shall be registered. You can find a link to JSC Form 1879 in Appendix D.
- b. Use the same form (JSC Form 1879) to decommission the alarm when it is no longer needed or required.
- c. Connect the alarm to the Emergency Dispatch Center for proper monitoring and response, if necessary.
- d. Develop written procedures for alarm use, calibration, and maintenance. Maintain documentation to show compliance with these requirements (dates, times, calibration results, maintenance issues). Keep the documentation or a copy with the alarm for Occupational Health safety and management inspection purposes.
- e. Include the appropriate alarm response by all occupants to all alarms found in the facility in the facility Emergency Action Plan. Brief or train facility occupants on this plan.
- f. Maintain a list of names and methods of contact (phone number, pager number) of work area responsible parties and keep it readily available for support during off-hour alarm activations.

6.11.7. Alarm testing

Before testing a chemical alarm, facility personnel shall first notify the Emergency Dispatch Center, if the alarm is connected to the Emergency Operations Center (EOC).

6.11.8. Responsibilities

- a. As a work area supervisor, you are responsible for:
 - (1) Performing hazard analyses for all potentially hazardous jobs or activities in your area of

JSC Safety and Health Requirements	JPR No.	1700.1
	Effective Date:	10/02/2024
	Expiration Date:	10/02/2029
	Page Number	Page 6.11-3 of 4

responsibility. Use procedures in Chapter 9.1. Occupational health consultation is available by calling x36726.

- (2) Registering the alarm with Occupational Health .
 - (3) Making sure calibrations and maintenance are performed at the specified frequency and keeping records at the alarm site to verify the alarm is reliable and working properly.
 - (4) Writing an emergency response plan specific to the alarm, training affected workers in the plan, and making the plan available to the Facility Manager.
 - (5) Providing help to JSC emergency responders during an alarm event.
 - (6) Ensuring remediation activities (ventilation, point source safing, etc.) by requesting support from the appropriate organizations.
- b. As a Facility Manager, you are responsible for:
- (1) Maintaining an inventory of all alarm systems in the facility.
 - (2) Maintaining a means of contacting responsible, knowledgeable support personnel for technical advice during an alarm event.
 - (3) Periodically inspecting the alarm and records to verify the alarm is properly maintained, calibrated, and working for its intended purpose.
 - (4) Verifying the alarm is properly registered by Occupational Health.
 - (5) Making sure the facility's Emergency Action Plan includes the chemical alarm systems and response requirements.
 - (6) Making sure all facility occupants and visitors are informed, briefed, or trained in alarm response requirements.
- c. Occupational Health is responsible for:
- (1) Maintaining an inventory of all chemical alarm systems.
 - (2) Assigning alarm registration numbers.
 - (3) Providing help to JSC emergency responders during an alarm event.
 - (4) Inspecting all registered alarms annually.
- d. The Emergency Dispatch Center is responsible for calling the Facility Manager and supporting personnel callback.
- e. The Security Office is responsible for enforcing perimeters around emergency scenes.
- f. JSC Fire Protection Specialists are responsible for providing initial response to calls received from the Emergency Dispatch Center after hazard detection alarms. Other aspects of the Emergency Action Plan, based on the initial response, may include:
- (1) Initiating the plan.
 - (2) Evacuating remaining nonessential personnel.
 - (3) Defining an area perimeter in an emergency.
 - (4) Performing industrial hygiene program air testing.

JSC Safety and Health Requirements	JPR No.	1700.1
	Effective Date:	10/02/2024
	Expiration Date:	10/02/2029
	Page Number	Page 6.11-4 of 4

(5) Developing specific controls for protecting response personnel.

g. The JSC Safety and Test Operations Division is responsible for:

(1) Providing support to the Emergency Dispatch Center in connecting alarms.

(2) Performing the duties required by JPR 1040.4, "JSC Emergency Preparedness Plan."